



HELIX MUST BE FORMED BY MATCHING METAL DIE (SIDE VIEW OF TRUE HELICAL FORM)

ž

- ūΞ HOT DIP GALVANIZE PER ASTM-A153 (LATEST REVISION).
- BASEPLATE TO BE PERPENDICULAR TO SHAFT AXIS (±1°) AND HOLE CENTERLINE CONCENTRIC (±, 188) TO SHAFT AXIS.

  STENCIL MIN. 1/2 IN. LETTERS MANUFACTURER'S NUMBER
- STENCIL MIN. 1/2 IN. AFTER GALVANIZING.
- PILOT POINT AND SHAFT AXES TO BE CONCENTRIC (±, 125 FIM) AND IN LINE (±2°),

4 ω

- ம் வ
- 7 FLAME CUT TWO SLOTS IN SHAFT PERPENDICULAR TO THE BASEPLATE, PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE, HELIX, AND PILOT POINT ON ALL WELDED AREAS.
  HELIX, AND PILOT POINT ON ALL WELDED AREAS.
  FLAMECUT IRREGULARITIES PERMISSIBLE: (1) VALLEYS NOT TO EXCEED 3/32 IN. BELOW NOMINAL SURFACE LEVEL, (2) PEAKS OR POSITIVE IRREGULARITIES NOT TO EXCEED 1/32 IN. ABOVE NOMINAL SURFACE LEVEL OR INTERSECTIONS OF NOMINAL SURFACES.
  WANNUFACTURER TO HAVE IN EFFECT INDUSTRY RECOGNIZED WRITTEN QUALITY CONTROL FOR ALL MATERIAL IS TO BE NEW, UNUSED AND MILL TRACEABLE MEETING THE FOLLOWING SPECIFICATIONS:

φ

- مِ
- BASEPLATE: ASTM A36-(LATEST REVISION) STRUCTURAL STEEL (CONFORM TO AASHTO TECH. BUL. #270)
- SHAFT: ASTM A252-(LATEST REVISION) GRADE 2, STEEL PIPE PILES. ALTERNATE MATERIAL: ASTM A53-(LATEST REVISION) TYPE E OR S, GRADE B, STEEL PIPE OR ASTM A500-(LATEST REVISION) GRADE B, STRUCTURAL STEEL TUBING.
- HELLIX: ASTM A635-(LATEST REVISION) 3/8" PLATE OR COIL. THICK HOT ROLLED STEEL
- PILOT POINT: ASTM A575-<LATEST REVISION)  $1-1/4^{\prime}$  DIAMETER HOT ROLLED STEEL BAR.
- HEX HEAD MACHINE BOLTS 1-8UNC-2A PER ANSI B-18.2. SAE J429 GRADE-5.
- 10. BASEPLATE IS PERMANENTLY STAMPED WITH MANUFACTURER'S IDENTIFICATION "ABC" IN 1/2" LETTERS AND DATE CODE IN 1/4" LETTERS.

  BASEPLATE PERMANENTLY MARKED TO INDICATE CABLEWAY OPENING IN SHAFT.

L	WITHOUT THE WRITTEN CONSENT OF HUBBELL POWER SYSTEMS. HUBBELL POWER SYSTEMS UNPUBLISHED	CONFIDENTIAL: THIS DRAWING AND ITS CONTENTS ARE CONFIDENTIAL AND THE EXCLUSIVE PROPERTY OF PUBBECATION.	CHANCE
DO NOT SCALE THIS DRAWING	SIZE DWG NO.		POOR SYSTEM, DC
DRN BY KSH	<sub>NO.</sub> SA11232JG4TL	FOUNDATION	<del>JUBBELL</del>
DATE 2/16/05	[L	ATION	POWER
SHEET 1/1	A REV		SYSTEM