



ž

- ΜH FINISH: HOT DIP GALVANIZE PER ASTM-A153 (LATEST REVISION). BASEPLATE TO BE PERPENDICULAR TO SHAFT AXIS (±1°) AND HOLE CENTERLINE CONCENTRIC (±, 188) TO SHAFT AXIS. STENCIL MIN. 1/2 IN. LETTERS MANUFACTURER'S NUMBER

4.

ω

- <u>ស</u> ល
- AFTER GALVANIZING.

  4. PILOT POINT AND SHAFT AXES TO BE CONCENTRIC (±.125 FIM) AND IN LINE (±2°).

  5. FLAME CUT TWO SLOTS IN SHAFT PERPENDICULAR TO THE BASEPLATE, FLAME CUT TWO SLOTS, HANDGRIND, AND CLEAN BASEPLATE,

  6. PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE,

  7. FLAMECUT IRREGULARITIES PERMISSIBLE: (1) VALLEYS NOT TO EXCEED 3/32 IN. BELOW NOMINAL SURFACE LEVEL, (2) PEAKS OR POSITIVE IRREGULARITIES NOT TO EXCEED 1/32 IN. ABOVE NOMINAL SURFACE LEVEL OR INTERSECTIONS OF NOMINAL SURFACES.

  8. MANUFACTURER TO HAVE IN EFFECT INDUSTRY RECOGNIZED WRITTEN QUALITY CONTROL FOR ALL MATERIALS AND MANUFACTURING PROCESSES.

  9. ALL MATERIAL IS TO BE NEW, UNUSED AND MILL TRACEABLE
- ω
- Φ

BASEPLATE: ASTM A36-(LATEST REVISION) STRUCTURAL STEEL (CONFORM TO AASHTO TECH. BUL. #270)

- SHAFT: ASTM A252-(LATEST REVISION) GRADE 2, STEEL PIPE PILES. ALTERNATE MATERIAL: ASTM A53-(LATEST REVISION) TYPE E OR S, GRADE B, STEEL PIPE OR ASTM A500-(LATEST REVISION) GRADE B, STRUCTURAL STEEL TUBING.
- HELL IX: ASTM A635-(LATEST REVISION)  $3/8^{\prime\prime}$  THICK HOT ROLLED STEEL PLATE OR COIL.
- PILOT POINT: ASTM A575-(LATEST REVISION)  $1-1/4^{\prime\prime}$  DIAMETER HOT ROLLED STEEL BAR.
- HEX HEAD MACHINE BOLTS 1-8UNC-2A PER ANSI SAE J429 GRADE-5. B-18, 2,
- 10. BASEPLATE IS PERMANENTLY STAMPED WITH MANUFACTURER'S IDENTIFICATION "ABC" IN 1/2" LETTERS AND DATE CODE IN 1/4" LETTERS.

  BASEPLATE PERMANENTLY MARKED TO INDICATE CABLEWAY OPENING IN SHAFT.
- 11.

OPII SOUMOO