





HELIX MUST BE FORMED BY MATCHING METAL DIE (SIDE VIEW OF TRUE HELICAL FORM)

ž

- 1. FINISH: HOT DIP GALVANIZE PER ASTM-A153 (LATEST REVISION).
  2. BASEPLATE TO BE PERPENDICULAR TO SHAFT AXIS (±1\*) AND HOLE CENTERLINE CONCENTRIC (±, 188) TO SHAFT AXIS.
  3. STENCIL MIN. 1/2 IN. LETTERS MANUFACTURER'S NUMBER AFTER GALVANIZING.
  4. PILOT POINT AND SHAFT AXES TO BE CONCENTRIC (±, 125 FIM) AND IN LINE (±2\*),
  5. FLAME CUT TWO SLOTS IN SHAFT PERPENDICULAR TO THE BASEPLATE.
  6. PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE,
  7. FLAMECUT IRREGULARITIES PERMISSIBLE: (1) VALLEYS NOT TO EXCEED 3/32 IN. BELOW NOMINAL SURFACE LEVEL, (2) PEAKS OR POSITIVE IRREGULARITIES NOT TO EXCEED 1/32 IN. ABOVE NOMINAL SURFACE LEVEL OR INTERSECTIONS OF NOMINAL SURFACES.
  8. MANUFACTURER TO HAVE IN EFFECT INDUSTRY RECOGNIZED WRITTEN QUALITY CONTROL FOR ALL MATERIALS AND MANUFACTURING PROCESSES.
  9. ALL MATERIAL IS TO BE NEW, UNUSED AND MILL TRACEABLE

ဖ

BASEPLATE: ASTM A36-(LATEST REVISION) STRUCTURAL STEEL (CONFORM TO AASHTO TECH. BUL. #270).

- SHAFT: ASTM A252-(LATEST REVISION) GRADE 2, STEEL PIPE PILES. ALTERNATE MATERIAL: ASTM A53-(LATEST REVISION) TYPE E OR S, GRADE B, STEEL PIPE OR ASTM A500-(LATEST REVISION) GRADE B, STRUCTURAL STEEL TUBING.
- HELLIX: ASTM A635-(LATEST REVISION)  $3/8^{\prime}$  THICK HOT ROLLED STEEL PLATE OR COIL,

PILOT POINT:

ASTM A575-(LATEST REVISION) 1-1/4" STEEL BAR.

DIAMETER

HOT ROLLED

- $3/4^*-10$  UNC X  $2-1/2^*$  HEX BOLT SAE J429 GRADE OR ASTM A193 GRADE B7.
- 10. BASEPLATE IS PERMANENTLY STAMPED WITH MANUFACTURER'S IDENTIFICATION "ABC" IN 1/2" LETTERS AND DATE CODE IN 1/4" LETTERS.
- 11. BASEPLATE PERMANENTLY MARKED TO INDICATE CABLEWAY OPENING IN SHAFT.

CONFIDENTAL: THIS DRAWING AND ITS CONTENTS ARE CONFIDENTAL AND THE EXCLUSIVE PROPERTY OF HUBBELL POWER SYSTEMS. NO PUBLICATION, DISTRIBUTION OF COPIES MAY BE MADE WITHOUT THE WRITTEN CONSENT OF HUBBELL POWER SCITTLES. CHANCE SB SA1 DWG NO. SA112-0648 DRN BY KSH UNDAT IGHTING DATE 10/29/04 | SHEET 1/1  $\overline{z}$ 

⊅₽

FOUNDATION *T112-0648*