



- FINISH: HOT DIP GALVANIZE PER ASTM-A153 (LATEST REVISION). BASEPLATE TO BE PERPENDICULAR TO SHAFT AXIS (±1°) AND HOLE CENTERLINE TO BE CONCENTRIC (±, 188) TO SHAFT AXIS.

 STENCIL MIN. 1/2 IN. LETTERS MANUFACTURER'S NUMBER AFTER GALVANIZING.

 PILOT POINT AND SHAFT AXES TO BE CONCENTRIC (±, 125 FIM) AND PILOT POINT AND SHAFT AXES.
- IN LINE (±2°)
- PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE,
 HELIX, AND PILOT POINT ON ALL WELDED PARTS.
 FLAMECUT IRREGULARITIES PERMISSIBLE: <1) VALLEYS NOT TO EXCEED
 3/32 IN. BELDW NOMINAL SURFACE LEVEL, <2) PEAKS OR POSITIVE
 IRREGULARITIES NOT TO EXCEED 1/32 IN. ABOVE NOMINAL SURFACE
 LEVEL OR INTERSECTIONS OF NOMINAL SURFACES.
 MANUFACTURER TO HAVE IN EFFECT INDUSTRY RECOGNIZED WRITTEN
 OUALITY CONTROL FOR ALL MATERIALS AND MANUFACTURING PROCESSES.

φ

- φ BASEPLATE IS PERMANENTLY STAMPED WITH MANUFACTURER'S IDENTIFICATION 'ABC' IN 1/2' LETTERS AND THE JULIAN DATE CODE IN 1/4' LETTERS.
 ALL MATERIAL IS TO MEET THE FOLLOWING SPECIFICATIONS:

م

BASEPLATE: ASTM A36-(LATEST REVISION) STRUCTURAL STEEL

- SHAFT: ASTM A252-(LATEST REVISION) GRADE 2, STEEL PIPE PILES. ALTERNATE MATERIAL: ASTM A53-(LATEST REVISION) TYPE E OR S, GRADE B, STEEL PIPE OR ASTM A500-(LATEST REVISION) GRADE B, STRUCTURAL STEEL TUBING.
- HELLIX: ASTM A635 (LATEST REVISION) 1/2' THICK HOT ROLLED STEEL OR COIL. PLATE
- PILOT POINT: ASTM A575 (LATEST REVISION) 1-1/4" DIAMETER HOT ROLLED STEEL BAR.
- HEX BOLT PER ANSI B-18.2.1, SAE J429 GRADE 1-8UNC-2A X 3-1/2" LG. HOT DIP GALV. PER ASTM A153
- NUTS HEAVY HEX NUTS PER ASTM ASTM A194 GRADE 2H DR ASTM A563 GRADE DH, MEETING THE SUPPLEMENTARY REQUIREMENTS DF ASTM A563; 1-8UNC-2B PER ANSI B18. 2. 2.
- 10. FLAME CUT TWO SLOTS IN SHAFT PERPENDICULAR TO THE BASEPLATE. BASEPLATE PERMANENTLY MARKED TO INDICATE CABLEWAY OPENING IN SHAFT.



LIGHTING CAT. NO. FOUNDATION T112-0284

HELIX MUST BE FORMED BY MATCHING METAL DIE (SIDE VIEW OF TRUE HELICAL FORM)

ALL RAI NORMAL

RADIAL SECTIONS

ιδ

ω

PITCH

VIEW "A-A"