



- FINISH: HOT DIP GALVANIZE PER ASTM-A153 (LATEST REVISION).
 BASEPLATE TO BE PERPENDICULAR TO SHAFT AXIS (±1°) AND HOLE
 CENTERLINE CONCENTRIC (±.188) TO SHAFT AXIS.
 STENCIL MIN. 1/2 IN. LETTERS MANUFACTURER'S NUMBER
 AFTER GALVANIZING.
 PILOT POINT AND SHAFT AXES TO BE CONCENTRIC (±.125 FIM) AND
 IN LINE (±2°).

- FLAME CUT TWO SLOTS IN SHAFT PERPENDICULAR TO THE BASEPLATE. PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE, PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE, PREHEAT, TUMBLEBLAST, HANDGRIND, AND CLEAN BASEPLATE, C1) VALLEYS NOT TO EXCEED 3/32 IN. BELOW NOMINAL SURFACE LEVEL, C2) PEAKS OR POSITIVE IRREGULARITIES NOT TO EXCEED 1/32 IN. ABOVE NOMINAL SURFACE LEVEL OR INTERSECTIONS OF NOMINAL SURFACES. MANUFACTURER TO HAVE IN EFFECT INDUSTRY RECOGNIZED WRITTEN QUALITY CONTROL FOR ALL MATERIALS AND MANUFACTURING PROCESSES. ALL MATERIAL IS TO BE NEW, UNUSED AND MILL TRACEABLE MEETING THE FOLLOWING SPECIFICATIONS:

BASEPLATE: ASTM A36-(LATEST REVISION) STRUCTURAL STEEL (CONFORM TO AASHTO TECH. BUL. #270).

- SHAFT: ASTM A252-(LATEST REVISION) GRADE 2, STEEL PIPE PILES. ALTERNATE MATERIAL: ASTM A53-(LATEST REVISION) TYPE E OR S, GRADE B, STEEL PIPE OR ASTM A500-(LATEST REVISION) GRADE B, STRUCTURAL STEEL TUBING.
- HELLIX: ASTM A635-(LATEST REVISION) 3/8" THICK HOT PLATE OR COIL. ROLLED STEEL
- PILOT POINT: ASTM A575-(LATEST REVISION) $1-1/4^{\prime}$ DIAMETER HOT ROLLED STEEL BAR.
- HEX HEAD MACHINE BOLT, 3/4-10UNC-2A PER ANSI B-18.2.1, SAE J429 GRADE 5.
- <u>10</u> BASEPLATE IS PERMANENTLY STAMPED WITH MANUFACTURER'S IDENTIFICATION "ABC" IN 1/2" LETTERS AND DATE CODE IN 1/4" LETTERS.

 BASEPLATE PERMANENTLY MARKED TO INDICATE CABLWAY OPENING IN SHAFT.

ALL RADIAL SECTIONS NORMAL TO AXIS ±3°

LIGHTING FOUNDATION CAT. NO. 7112-0647

HELIX MUST BE FORMED BY MATCHING METAL DIE

ALL RADIAL SECTIONS

88

PITCH

(SIDE VIEW OF TRUE HELICAL FORM)



ž